

TEST CERTIFICATE

Issued to: Alfanar Electrical Systems L.L.C.
P.O. Box 282735
Dubai
United Arab Emirates

For the product: Empty enclosure for low-voltage switchgear and controlgear assemblies

Trade name: Alfanar / Contactum

Type/Model: Metal enclosures with normal door

Ratings: IP66, IK10, indoor / outdoor
For more details see annex

Manufactured by: Alfanar Electrical Systems L.L.C.
P.O. Box 282735
Dubai
United Arab Emirates

Subject: Type tests

Requirements: IEC 62208:2011
Clauses 9.3, 9.4, 9.6, 9.7, 9.8, 9.11, 9.12, 9.13 and 9.14

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2190013.02-INC, dated 16 May 2017.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 16 May 2017

Number: 2190013.101

DEKRA Certification B.V.

H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



DEKRA

